

Addendum to SC1502 – Huntington/Milltown Rural Fire Station

Specifications

1. All bids priced as specified. In addition each bid shall have the price of provided concrete omitted to the right of the bid and listed as "Bid Less Concrete". Owner may opt to provide concrete to site.
 - b. Thickness of slab to read 6" (in), not 6' (ft).
5. Building will have 3" reinforced vinyl backed insulation in roof and walls
6. Supply and install 7'6" tall Rpanels around interior of building.